


System No. HW-D-0137



ANSI/UL2079	CAN/ULC S115
Assembly Ratings- 1 and 2 Hr (See Item 2)	F Ratings - 1 and 2 Hr (See Item 2)
Nominal Joint Width - 1-1/2 In.	FT Ratings - 1 and 2 Hr (See Item 2)
Class II Movement Capabilities - 50% Compression or Extension	FH Ratings - 1 and 2 Hr (See Item 2)
L Rating At Ambient - Less Than 1 CFM/sq ft	FTH Ratings - 1 and 2 Hr (See Item 2)
L Rating At 400 F - Less Than 1 CFM/sq ft	Nominal Joint Width - 1-1/2 In
	Class II Movement Capabilities - 50% Compression or Extension
	L Rating At Ambient - Less Than 1 CFM/sq ft
	L Rating At 400 F - Less Than 1 CFM/sq ft



1. **Floor Assembly** - The fire-rated fluted steel deck/concrete floor assembly shall be constructed of the materials and in the manner described in the individual D900 Series Floor-Ceiling Design in the UL Fire Resistance Directory and shall include the following construction features:
 - A. **Steel Floor and Form Units*** - Max 3 in. (76 mm) deep galv steel fluted floor units having a min valley width of 4-3/4 in. (121 mm).
 - B. **Concrete** - Min 2-1/2 in. (64 mm) thick reinforced concrete, as measured from the top plane of the floor units.
As an alternate to the steel deck/concrete floor, the floor assembly may consist of a min 4-1/2 in. (114 mm) thick steel-reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete slab.
- 1A. **Roof Assembly** - (Not Shown) - As an alternate to the floor assembly (Item 1), a fire rated fluted steel deck roof assembly may be used. The roof assembly shall be constructed of the materials and in the manner described in the individual P900 Series Roof-Ceiling Design in the UL Fire Resistance Directory. The hourly fire rating of the roof assembly shall be equal to or greater than the hourly fire rating of the wall assembly. The roof assembly shall include the following construction features:
 - A. **Steel Roof Deck** - Max 3 in. (76 mm) deep galv steel fluted roof deck having a min valley width of 4-3/4 in. (121 mm).
 - B. **Roof Insulation** - Min 2-1/4 in. (57 mm) thick poured insulating concrete, as measured from the top plane of the steel roof deck.
 - C. **Roof Covering*** - Hot-mopped or cold-application materials compatible with insulation concrete.



Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876

Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: November 9, 2011



2. **Wall Assembly** - The 1 or 2 hr fire-rated gypsum board/stud wall assembly shall be constructed of the materials and in the manner described in the individual U400, V400 or W400 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:

- A. **Floor Runners** - (Not Shown)-Floor runners of wall assembly shall consist of min No. 25 gauge galv steel channels sized to accommodate steel studs.
- B. **Light Gauge Framing*-Slotted Ceiling Runner** - Ceiling runner to consist of galv steel channel with slotted flanges sized to accommodate steel studs. Ceiling runner to be centered beneath valley of steel floor or roof deck when steel deck/concrete floor is used. Flange height of ceiling runner shall be min 1/4 in. (6 mm) greater than max extended joint width. Ceiling runner secured with steel fasteners spaced max 24 in. (610 mm) OC.

BRADY CONSTRUCTION INNOVATIONS INC,

DBA SLIPTRACK SYSTEMS - SLP-TRK

CALIFORNIA EXPANDED METAL PRODUCTS CO - CST

CLARKDIETRICH BUILDING SYSTEMS - Type SLT, SLT-H

MARINOWARE, DIV OF WARE INDUSTRIES

INC - Type SLT

METAL-LITE INC - The System

SCAFCO STEEL STUD MANUFACTURING CO

STEELER INC - Steeler Slotted Ceiling Runner

TELLING INDUSTRIES L L C - True-Action Deflection Track

- C. **Studs** - Steel studs to be min 3-1/2 in. (89 mm) wide. Studs cut 1/2 to 1-1/4 in. (13 to 32 mm) less in length than assembly height with bottom nesting in and resting on floor runner and with top nesting in slotted ceiling runner. Steel studs secured to slotted ceiling runner with No. 8 by 1/2 in. (13 mm) long wafer head steel screws at midheight of slot on each side of wall. Stud spacing not to exceed 24 in. (610 mm) OC.

- C1. **Light Gauge Framing* -Slotted Studs** - Slotted steel stud to be used in conjunction with **Light Gauge Framing* -Floor and Ceiling Runners** (Item 2B1). Slotted steel studs to be min 3-1/2 in. (89 mm) wide. Slotted steel studs cut 1/2 in. to 3/4 in. (13 to 19 mm) less in length than assembly height with bottom nesting in and secured to both ceiling and floor runners. Ceiling runner secured to preformed slot within steel stud by means of No. 10 by 3/4 in. (19 mm) long low profile head steel screw. Floor runner attached to bottom of steel stud by means of No. 8 by 1/2 in. (13 mm) long pan head steel screw. Slotted steel stud spacing not to exceed 24 in. (610 mm) OC.

STEELER INC - Steeler Slotted Stud

- D. **Gypsum Board*** - Gypsum board sheets installed to a min total 5/8 in. (16 mm) or 1-1/4 in. (32 mm) thickness on each side of wall for 1 and 2 hr rated assemblies, respectively. Wall to be constructed as specified in the individual U400 Series Design in the UL Fire Resistance Directory, except that a max 1 in. (25 mm) gap shall be maintained between the top of the gypsum board and the lower surface of the steel floor or roof deck and the top row of screws shall be installed into the studs 3 to 3-1/2 in. (76 to 89 mm) below the lower surface of the floor or roof.

The hourly fire rating of the joint system is equal to the hourly fire rating of the wall.

3. **Joint System - Max separation between bottom of floor or roof deck and top of gypsum board (at time of installation of joint system) is 1-1/2 in. (38 mm). The joint system is designed to accommodate a max 50 percent compression or extension from its installed width.** The joint system shall consist of forming and fill materials, as follows:

- A. **Forming Material*** - Min 5/8 in. (16 mm) or 1-1/4 in. (32 mm) wide sections of mineral wool batt insulation for 1 or 2 hr rated assemblies, respectively. Sections of mineral wool compressed 50 percent in thickness and installed cut edge first to fill the gap between the top of the gypsum board and the bottom of the steel deck or the concrete floor slab. The forming material shall be installed flush with both surfaces of wall.

IIG MINWOOL L L C - MinWool-1200 Safing

ROCK WOOL MANUFACTURING CO - Delta Board

ROCKWOOL MALAYSIA SDN BHD - SAFE

ROXUL INC - SAFE

THERMAFIBER INC - Type SAF



Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876

Reproduced courtesy of Underwriters Laboratories, Inc.

Created or Revised: November 9, 2011

(800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com



HW-D-0137
PAGE 2 OF 3

- B. **Fill, Void or Cavity Material*-Sealant** - Min 1/8 in. (3.2 mm) wet thickness or 1/16 in. (1.6 mm) dry thickness of fill material spray applied on each side of the wall between the top of the wall and the bottom of the steel floor or roof deck and overlap a min 1/2 in. (13 mm) onto gypsum board on both sides of wall. Additional 1/8 in. (3.2 mm) wet thickness or 1/16 in. (1.6 mm) dry thickness of fill material shall overlap a min 1/2 in. (13 mm) onto the steel deck or concrete on both sides of the wall.

SPECIFIED TECHNOLOGIES INC - SpecSeal AS200 Elastomeric Spray

*Bearing the UL Classification Mark



Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876

Reproduced courtesy of Underwriters Laboratories, Inc.

Created or Revised: November 9, 2011

(800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com



HW-D-0137
PAGE 3 OF 3